



Norfolk

Department of Planning & Community Development

CHECKLIST FOR ELECTRICAL PLAN REVIEW

Requirements

- UL number is required for signs

Electrical service for the following requires a one-line diagram with the seal of an architect or engineer:

- Over 3 stories
- Over 600 volts
- Over 800 amps

The exception is when both the design and installation are done by a licensed master electrician or a Class A electrical contractor.